



Almost?



Foundation wall penetration.
Requires sleeve and fernco coupling.



If 18" of clearances is the minimum?

Should 16" ok?



Nice installation—outside wall is well insulated and all areas are well sealed with sheetrock to prevent air infiltration. Makes the installation an interior installation rather than an exterior installation. Good energy efficient installation.



This tank likely will soon find a
way to tip over!
First big rain—or next spring
snow melt



This is not a good installation—large covered porch/deck. The 6 x 6 short posts actually miss the outside beam and are not located well on the center of the forms. How are the 6 x 6 post attached?



Gotta-get the wire through somehow—
protected half of it!



Was the screw meant to hold the wire in place?



Tell me again—half of the hanger fit —
so why is this supposed to be ok?



All that weight—all those big LVLs
.... You say Toe-nailed!—what no hangers?